

CCSI

Carbon Capture Simulation Initiative

Risk-Based Cost Methods

Dave Engel

Pacific Northwest National Laboratory
Richland, WA, USA


IEA CCS Cost Workshop
Paris, France
November 6-7, 2013




U.S. DEPARTMENT OF
ENERGY

Carbon Capture Challenge

- The **traditional pathway** from discovery to commercialization of energy technologies is long¹, i.e., ~ **20-30 years**.
- Technology innovation increases the cost growth, schedule slippage, and the probability of operational problems.²
- President's plan³ requires that barriers to the widespread, safe, and cost-effective deployment of CCS be overcome **within 10 years**.
- To help realize the President's objectives, new approaches are needed for taking concepts **from lab to power plant, quickly, at low cost and with minimal risk**.






CCSI will accelerate the development of CCS technology, from discovery through deployment, with the help of **science-based simulations**



Source: Ciferno, "DOE/NETLs Existing Plants."

1. International Energy Agency Report: Experience Curves for Energy Technology Policy," 2000
 2. RAND Report: "Understanding the Outcomes of Mega-Projects," 1988;
 3. <http://www.whitehouse.gov/the-press-office/presidentialmemorandum-a-comprehensive-federal-strategy-carbon-capture-and-storage>

For Accelerating Technology Development



Identify promising concepts



Reduce the time for design & troubleshooting



Quantify the technical risk, to enable reaching larger scales, earlier



Stabilize the cost during commercial deployment

National Labs




Academia



Industry



Advanced Computational Tools to Accelerate Next Generation Technology Development




Risk Analysis Role in Facilitating Acceleration

Risk Analysis Role in Facilitating Acceleration

Enable industry users to incorporate their current state of knowledge, resources, and capabilities into the Risk Analysis and Decision Making Tool Ensemble to make sound judgment about R&D directions—moving along the TRL scales or skipping scales—with confidence and resolve, without comprising system reliability, maintainability, and supportability objectives.

Enable and Empower Users in CC R&D Decisions



Development Roadmap and Value to End Users

Process Modeling and Optimization

Cost Model

Cost is calculated using an optimized steady-state system process model (Aspen plus) as shown below:

Objective Function - Levelized Cost of Electricity

$$LCOE = \frac{(CCF)(TPC) + (LFF)(OCF) + (LFV)(CF)(OCV) + (LFC)(CF)(CCV)}{(CF)(MWh)}$$

CCF : Capital cost factor (0.175)

TPC : Total plant capital (reference plant + capture and compression)

CF : Capacity factor (0.85)

LFF, LFV, LFC : Levelization factor for fixed, variable, and coal costs (1.1568, 1.1568, and 1.2022)

OCF, OCV, OCC : Total operating fixed, variable, and coal costs

MWh : Annual net megawatt-hours of power generated at 100 % capacity


Constraint - CO₂ Capture

$$\frac{CO_2 \text{ mol flow rate to sequestration}}{C \text{ mol flow rate in boiler's feed}} \geq 90\%$$

Cost is then passed to the Risk Analysis models for use in the Financial Risk Model

Process Modeling and Optimization Cost Model



Modular Framework Retrofit to a 550 MW Subcritical PC Plant



Sample Results


	Typical	Base Case	2x Q	4x Q	2x α	4x α	4x Q, 4x α
CO ₂ Permeance (GPU)	10-10000 ⁺	1000 ⁺	2000	4000	1000	1000	4000
Ar Selectivity	N/A	20	20	20	40	80	80
H ₂ O Selectivity	<1	0.5	0.5	0.5	0.5	0.5	0.5
N ₂ Selectivity	4-150 ⁺	50 ⁺	50	50	100	200	200
O ₂ Selectivity	N/A	20	20	20	40	80	80
LCOE (\$/MWh)	N/A	136	131	130	130	126	116
LCOE inc Reference Plant (%)	N/A	113	105	103	103	97	81

LCOE Cost Distribution



Result (units)	Base Case	2x Q	4x Q	2x α	4x α	4x Q, 4x α
Relative vol. increase of FG (%)	16	18	21	12	11	13
Makeup air (m ³ /hr/10 ³)	83	112	163	52	36	68
Oxygen depletion (%)	2.8	4.1	6.9	1.3	0.7	2.2
FG CO ₂ concentration (mol%)	17	17	17	18	18	18
Membrane area (m ² /10 ⁶)	1.13	0.85	0.64	1.14	1.16	0.75
Membrane skid cost (\$/10 ⁶)	57	43	32	57	58	36
Compression eq. cost (\$/10 ⁶)	83	81	82	75	72	64
Net Output (MW)	409	411	407	422	430	440

Coupled CCSI Risk Analysis and Decision-Making Framework



Integrating Probabilistic Risk Analysis and Uncertainty Quantification cross Models

Financial Risk Model

Only numbers in BOLD blue are user selectable

Rate, Tax and Growth Assumptions	Value	Units
Utility PPA per MWh	60	\$ per MWh
PPA Inflation Rate	1.5%	Percent
Federal tax rate	35%	Percent
State tax rate	7.0%	Percent
Discount rate	7.0%	Percent
Tax life of plant	30	Years
Federal PTC	0.0%	Percent
Federal ITC	30.0%	Percent
State ITC	7.0%	Percent
State PTC multiplier	1	Units

Electric v. Thermal Power Production	Value	Units
Electric Power Output	650	MWe
Thermal Power Output	1759	MWth

Replacement Power	Value	Units
CCS Parasitic Power Requirements	210	MWe
CCS Parasitic Power Recirculating Fraction	0.3231	-
Plant Average Hours of Operation per Day	20	hours/day
Plant Average Days of Operation per Year	350	days/year
Plant Capacity Factor without CCS	0.799	-
Drop in Duty Factor due to CCS	5.0%	percent
Duty Factor with CCS	0.759	-
Replacement Power Required	236	MWe
Unit Cost of Replacement Power	60.0	\$/MWe

Plant Construction Expenses	Value	Units
Total Capital Costs	2	\$B
Construction Period	2	Years

Operating Expenses	Value	Units
Operating Expense Inflation Rate	1.5%	Percent
Carbon Capture Percentage	90.0%	Percent
Carbon Tax	25	\$ per ton
Fixed O&M Base Year Cost	23	\$/M
Variable O&M Cost per mWh	4.25	\$ per MWh

Carbon Capture Retrofit	Value	Units
CCS Construction Costs	1.600	\$B
CCS Fixed O&M Costs	50	\$/year
Variable O&M Costs	0.0087	\$ per kW
Construction Period	2	years

Uncertainty Distribution			
Min	Max	Average	Random

Min	Max	Average	Random

Min	Max	Average	Random
160	260	210	211
0%	10%	5%	5.1%


Min	Max	Average	Random

Min	Max	Average	Random
85.0%	95.0%	90.0%	90.0%

Min	Max	Average	Random
0.5	3.0	1.6	1.7
25.0	100.0	50.0	62.5


Financial Risk Model

	No Capture	Carbon Capture	Difference
Power Generation for Sale (MW)	650	413	-36.5%
Total Revenue - NPV (\$)	3,447,250,773	3,447,250,773	0.0%
Total Operating Expenses - NPV (\$)	449,584,381	1,868,708,398	315.7%
Depreciation Expense - NPV (\$)	796,116,764	1,125,018,224	41.3%
Income Taxes - NPV (\$)	962,191,240	363,802,699	-62.2%
Tax Credits - NPV (\$)	668,966,722	987,281,376	47.6%
Carbon Taxes - NPV (\$)	1,040,249,355	553,601,631	-46.8%
Discounted Present Value of Net Receipts (\$)	868,075,754	523,401,198	-39.7%



Uncertain CCS Parameter	Rank	Relative Importance
CCS Parasitic Power Requirements	1	690
Drop in Duty Factor due to CCS	4	86
Carbon Capture Percentage	3	366
CCS Construction Costs	5	1
CCS Fixed O&M Costs	2	627

Update Ranking



Technical Risk System Mechanical Model

- Application based on a prototype hybrid solid sorbent system
- A series of RBD describes the system as interconnected functional blocks; failure of any block prevents the operation of the system.
- The estimation of failure rate and MDT of each component /function block allows a calculation of MTBF, MDT, and U for any components, blocks, combinations of blocks, or for the whole system.








Figure A.1 Process Flow Diagram (Lee et al. 2012, p. 16)



$$U_s = \frac{\sum_i \lambda_i MDT_i}{1 + \sum_i \lambda_i MDT_i}$$





Maturity Modeling: Technology Readiness Level



Major Objectives of Risk Analysis and Decision Making

1. Formulate risk acceptance metrics and processes relevant to capital investors and other stakeholders that can be integrated into the simulation framework (CCSI Objective 3)
2. Provide connectivity between plant-cost scaling factors for each technology option and economic market influences such as finite resources of specialized labor and materials (CCSI Objective 1)
3. Combine technical risk and financial risk factors into an integrated decision analysis framework that naturally handles propagation of uncertainties into a variety of decision metrics (CCSI Objective 1 & 3)

Technology Readiness Level (TRL)

Measure used to assess the maturity of evolving technologies prior to incorporating the technology into a system/subsystem (Mankins, 1995, NASA). The qualitative TRL can be used to roughly estimate the uncertainty bounds in a comparison of technologies (Mathews, 2010). This methodology will be used to help quantify technical risks and used to accomplish Risk Analysis Objectives 2 and 3.

- Yard stick to measure accelerated development against traditional development
- Introduce uncertainty into framework of technical risk model




Technology Maturity Models

Significance

- Technology maturity modeling is the foundational step in CCSI Probabilistic Risk Analysis
- Without including the maturity uncertainties, models under-estimate uncertainties and possibly over-estimate performance and profitability estimates, especially at low TRLs

Methods

- TRL input is entered into the GUI of the expert elicitation system
- The model calculates the likelihood of the technology being at a certain maturity level
- Uncertainty factor distributions (ranges) are then modeled for each maturity level and used in the uncertainty analysis to simulate uncertainty factors to be used in the modeling of the technical and financial risks.




TRL Likelihood Model

Technology Readiness Levels

9	Commercial operation in relevant environment	
8	Commercial demonstration, full scale deployment in final form	650 MW
7	System prototype in an operational environment	>100 MW
6	Fully integrated pilot (prototype) tested in a relevant environment	10 - 50 MW
5	Component validation in relevant environment (coal plant)	1 MW
4	Component validation tests in laboratory environment	1 KW
3	Analytical and experimental critical function proof-of-concept	
2	Formulation of application	
1	Basic principals	

$$P(TRL_i) = \binom{n}{k} p^k (1 - p)^{n-k}$$






TRL 3: Has analytical and experimental proof-of-concept been demonstrated in a laboratory environment?

- Have experiments validated the predicted capability of technology components? Yes No
- Have analytical studies verified performance predictions and produced algorithms? Yes No
- Are the technology or system performance metrics established? Yes No
- Can science relevant to developing the technology be modeled or simulated? Yes No
- Have technology or system performance characteristics been confirmed and documented with representative data sets? Yes No
- Do experiments or modeling and simulation (M&S) validate performance predictions of technology capability? Yes No
- Do the results of technical application experiments verify the feasibility of such applications? Yes No
- Does published research provide evidence for successful integration of technology and system components? Yes No
- Have design techniques been identified and/or developed? Yes No
- Have scaling studies been initiated? Yes No
- Has analysis of alternatives been completed? Yes No
- Have programmatic risks been identified and mitigation strategies been documented? Yes No

TRL Uncertainty Model

TRL uncertainty Factors



TRL	Min	Max	Mode	P(mode)
0	0.44	7.0	1.0	0.3
1	0.45	4.2	1.0	0.3
2	0.46	3.9	1.0	0.3
3	0.48	3.5	1.0	0.3
4	0.50	3.2	1.0	0.3
5	0.52	2.8	1.0	0.3
6	0.55	2.5	1.0	0.3
7	0.58	2.1	1.0	0.3
8	0.64	1.8	1.0	0.3
9	0.72	1.5	1.0	0.3



$$U = \gamma_0 F(x_0) + \gamma_1 F(x_1) + \dots + \gamma_9 F(x_9)$$

$$\gamma_i = \alpha_i \prod_{j=i+1}^9 (1 - \alpha_j)$$

(Cost) Uncertainty Factor Distributions



TRL uncertainty Factors

TRL	Min	Max	Mode	P(mode)
0	0.44	7.0	1.0	0.3
1	0.45	4.2	1.0	0.3
2	0.46	3.9	1.0	0.3
3	0.48	3.5	1.0	0.3
4	0.50	3.2	1.0	0.3
5	0.52	2.8	1.0	0.3
6	0.55	2.5	1.0	0.3
7	0.58	2.1	1.0	0.3
8	0.64	1.8	1.0	0.3
9	0.72	1.5	1.0	0.3

Capital and levelized costs of a SCR system for a standard (500 MWe, burning medium sulfur coal, 80% NO_x removal) new coal-fired power plant.

SCR: selective catalytic reduction systems at standard U.S. coal-fired utility plants, used for the removal of NO_x.

- Studies based on low-sulfur coal plant, which requires lower SCR capital cost
- Studies evaluated prior to any commercial SCR installation on a coal-fired utility plant

Yeh, S, E Rubin, et al. Uncertainties in Technology Experience Curves for Integrated Assessment Models. *Environmental Science & Technology*, Vol. 43, No. 18, pp. 6907-6914, 2009.

Implications for Cost Modeling

- Costs are calculated/simulated using a steady-state optimal system process model. The simulations incorporate parameter (aleatory) uncertainties (call these known unknowns)
- This modeling ignores uncertainties due to lack of knowledge caused by the lack of technical maturity (epistemic uncertainties or unknown unknowns)
- Our risk analysis models incorporate the TRL uncertainty modeling to address the epistemic uncertainties and the mechanical risk model to address the reliability (maintenance) of the system.
- Without incorporating these models, the results under-estimate the uncertainties of the system and possibly over-estimate the performance
provides more realistic comparison of technologies and identifies large sensitive areas (processes and parameters) to help accelerate the technology development

Future Development

- Transition model to identify potential TRL up-scaling pathways and challenges
- Incorporate likelihood model uncertainties
- Develop multi-process maturity modeling capability (e.g., adsorber, regenerator, and transport)
- Operationalize the System Flow Diagram for CCSI Decision Making Framework

Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

For further information contact
Dave Engel, PNNL
dave.engel@pnnl.gov

